

District Water Testing Laboratory

Office of Executive Engineer, Construction Division U.P. Jal Nigam(Rural) Kasganj Water Test Report

To, S.J.S. Public School Tayal Camound Soron Road Kasganj Distt. Kasganj.

Water Analysis Report no. 07 Dated 30-05-2022 Name of Sample Collector/Designation: Sri. Sandeep Sample Collection Dated 25-05-2022

Type of Source:- RO Block: Kasganj

Sample Code 07 Disst: Kasganj


	Panchayat : Nagar Palika Kas	Kasganj Village:Soron Road Kasganj		Source Location: S.J.S. Public School		
S. No.	Parameter (Unit)	BIS Acceptable Limit	BIS Permissible Limit in Absence of alternate source	Unit Mg/I	Test Results	Commet
1	Turbidity (NTU)	1	5	NTU	0.09	
2	Colour	5	25	PCS		
3	рН	6.5-8.5	6.5-8.5		7.64	
4	TDS	500	2000	Mg/I	305	
5	Total Hardness (as CaCO3)	200	600	16	140	
6	Chloride (CI)	250	1000		15.4	
7	Alkalinity (as CaCO3)	200	600		128	
8	Nitrate (as NO3)	45	45	4	3.90	
9	Iron (as Fe)	0.1	0.3	41	0.09	
10	Fluoride (as F)	0.1	1.5		0.18	
11	Sulphate (as SO4)	200	400		2.10	
12	Calcium	75	200		-	
13	Magnesium	30	100			
14	Other Parameter					1,-

Remark : Satisfactory.


Tested By, (Chemist)

Kasganj

Junior Engineer U.P. Jal Nigam, Kasganj Assistant Engineer U.P. Jal Nigam, Kasganj







SWACHH VIDYALAYA PURASKAR 2021-22 District Level Award

District Collector

Sub Category Wise Self-evaluation Seons

Spanned with CamScanner